



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ  
Dilovası OSB Mahallesi Fırat Caddesi No: 18  
Dilovası, Kocaeli / TÜRKİYE  
www.effectis.com

## DECLARATION OF TEST RESULTS

No: ERA-2100-0018

The related reaction to fire tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory 20<sup>th</sup> October 2021. Classification of reaction to fire has been carried out in accordance the standard:

**EN 13501-1:2018**

### "Sanwich Door Panel"

Fire behaviour		Smoke production		Flaming droplets
C	-	s	3	, d 0

### Flammability Classification\*

**Hardly inflammable**

\*Turkey's regulation on fire protection 2009, Appendix-2/Ç the table of flammability classification of construction materials in accordance with EN 13501-1

Placed on the market by: BİLKA OTOMATİK KAPI SİS. LOJİSTİK İNŞ. SAN. VE TİC. LTD. ŞTİ.  
Mimarsinan O.S.B. 9. Cad. No:01 Melikgazi, Kayseri / TURKEY

Manufactured by: BİLKA OTOMATİK KAPI SİS. LOJİSTİK İNŞ. SAN. VE TİC. LTD. ŞTİ.  
Mimarsinan O.S.B. 9. Cad. No:01 Melikgazi, Kayseri / TURKEY

PUR Foam Manufacturer: PLUSKİM KİMYA SAN ve TİC A.Ş.  
Selahaddin Eyyübi Mah. 1625. Sokak No:2 Esenyurt /  
TURKEY

Ali BAYRAKTAR  
Laboratory Manager  
25.10.2021

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: ERA-21-156.

